

TEST REPORT

Applicant: SUNLIGHT ECO-TECH LIMITED
UNIT D 2/F SPEEDY IND BLDG
114 HOW MING ST
KWUN TONG
KLN HK

Date: Jun 15, 2020

Attn: MARTIN Z.LI


Sample Description As Declared :

No. Of Sample : Several
Buyer's Name : -
Agent's Name : -
Manufacturer's Name : Sunlight Eco-Tech Limited
Sample Description : Mask
Colour : Blue
Style No. : -
Order No. / PO No. : -
Product End Uses : -
Fibre Content : -
Fabric/GMT Weight : -
Ref. : -
Date Received/Date Test Started : Apr 08, 2020

Applicant's Provided Care Instruction/Label :

-

For and on behalf of
Intertek Testing Services Hong Kong Limited




Teddy Y. N. Chung
Director



TEST REPORT

Original Sample Photo:




For any queries on this report, you are welcome to contact our customer service representatives:

EM3

Rebecca Chan at (852) 63290431 or email to rebecca.chan@intertek.com

Angie Yu (852) 98639123 or email to angie.yu@intertek.com

For and on behalf of
Intertek Testing Services Hong Kong Limited



Teddy Y. N. Chung
Director



TEST REPORT

Tests Conducted (As Requested By The Applicant)

1 Bacteria Filtration Efficiency (BFE) and Differential Pressure (Delta P) GLP Report:

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.7 - 3.0 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu\text{m}$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

The Delta P test is performed to determine the breathability of test articles by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test complies with EN 14683:2019, Annex C and ASTM F2100-19.

All test method acceptance criteria were met.

Test side: Blue Side

BFE Test Area: $\sim 40 \text{ cm}^2$

BFE Flow Rate: 28.3 Liters per minute (L/min)

Delta P Flow Rate: 8 L/min

Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours

Test Article Dimensions: $\sim 178 \text{ mm} \times \sim 171 \text{ mm}$

Positive Control Average: 2.9×10^3 CFU

Negative Monitor Count: < 1 CFU

MPS: $3.0 \mu\text{m}$

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Bacteria Filtration Efficiency (Cont'd)

Results:

Test Article Number	Percent BFE (%)
1	99.8
2	99.7
3	99.5
4	99.7
5	99.6

Test Article Number	Delta P (mm H ₂ O/cm ²)	Delta P (Pa/cm ²)
1	3.3	31.9
2	3.4	33.7
3	3.3	32.3
4	3.4	33.3
5	3.5	33.9

The filtration efficiency percentages were calculated using the following equation:

$$\%BFE = \frac{C - T}{C} \times 100$$

C= Positive control average

T= Plate count total recovered downstream of the test article

Note: The plate count total is available upon request

Test Article Preparation: The test articles were conditioned for a minimum of 4 hours at 21 ± 5°C and 85 ± 5% RH, prior to BFE and Delta P testing.

Test Method Acceptance Criteria: The BFE positive control average shall be maintained at 1.7 – 3.0 x 10³ CFU.

The MPS control average of the challenge aerosol shall be maintained at 3.0 ± 0.3 µm.

The Delta P test flow rate shall be maintained at 8 L/min throughout the testing.

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Bacteria Filtration Efficiency (Cont'd)

Procedure:

BFE: A culture of *S. aureus*, ATCC #6538, was diluted in peptone water (PEPW) to yield challenge level counts of $1.7 - 3.0 \times 10^3$ CFU per test article. The bacterial culture suspension was pumped through a nebulizer at a controlled flow rate and fixed air pressure. The constant challenge delivery, at a fixed air pressure, formed aerosol droplets with a MPS of approximately $3.0 \mu\text{m}$. The aerosol droplets were generated in a glass aerosol chamber and drawn through a six-stage, viable particle, Andersen sampler for collection. Test articles, positive controls, and reference material received a one minute challenge followed by a one minute vacuum cycle.

The Andersen sampler, a sieve sampler, impinged the aerosol droplets onto six soybean casein digest agar (SCDA) plates based on the size of each droplet. The agar plates were incubated at $37 \pm 2^\circ\text{C}$ for 48 ± 4 hours and the colonies formed by the bacteria laden aerosol droplets were then counted and converted to probable hit values using the positive hole conversion chart provided by Andersen. These converted counts were used to determine the average challenge level delivered to the test articles. The distribution ratio of the colonies on each of the six agar plates was used to calculate the MPS of the challenge aerosol.

Delta P: The Delta P test simply measured the differential air pressure on either side of the test article using an incline, "U" tube, or digital manometer. Testing was conducted at a flow rate of 8 L/min (volumetric). At least one reference material is included with each set of test articles.

The Delta P values were reported in mm water/cm² and Pa/cm² of test area and calculated using the following equation:

$$\text{Delta } P = \frac{\bar{M}}{A}$$

Where: \bar{M} = Average mm of water of the test replicates per test article

A = Area of the test article holder (cm²)

The test article holder used in the Delta P test has a test area of 4.9 cm².

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Bacteria Filtration Efficiency (Cont'd)

Compliance Statement: The test was conducted in accordance with the USFDA (21 CFR Parts 58, 210, 211 and 820) Regulations. This final report reflects the raw data.

Activity	Date
Study Initiation	30 Apr 2020
Phase Inspected by Quality Assurance: Delta P Measurements	19 May 2020
Audit Results Reported to Study Director	01 Jun 2020
Audit Results Reports to Management	01 Jun 2020

Data Disposition: The study plan, raw data and final report from this study are archived at competent subcontractor laboratory.

Remark: The test was conducted by competent subcontractor laboratory.

End of Report

When a statement of conformity to a specification or standard is provided on test report, the decision rule shall be applied. For details, please refer to the latest version of Intertek's "Decision Rule Information" and is available on Intertek's website. <https://intertekhk.qrd.by/decision-rules-info>. If decision rule already inhered in the requested specification or standard, Intertek's "Decision Rule Information" is not applicable.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to and subject to our standard Terms and Conditions which can be obtained at our website: <http://www.intertek.com/terms/>. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Intertek is responsible for all the information provided in the reports, except when information is provided by the Client or when the Client requires the item to be tested acknowledging a deviation from specified conditions that can affect the validity of results.

The observations and test results in this report are relevant to the sample(s) tested and submitted by client. The report is not intended to be a recommendation for any particular course of action, you are responsible for acting as you see fit on the basis of the report results. This report does not discharge or release you from your legal obligations and duties to any other person. Only the Client is authorized to permit copying or distribution of this report and the report shall not be reproduced except in full. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

