

TEST REPORT

Applicant: SUNLIGHT ECO-TECH LIMITED
UNIT 507 ENTERPRISE PLACE
5 SCIENCE PARK WEST AVENUE
SHATIN
NT HK

Date: May 27, 2020

Attn: MARTIN Z.LI

Sample Description As Declared :


No. Of Sample : Several
Buyer's Name : -
Agent's Name : -
Manufacturer's Name : Sunlight Eco-Tech Limited
Sample Description : Mask
Colour : Blue
Style No. : -
Order No. / PO No. : -
Product End Uses : -
Fibre Content : -
Fabric/GMT Weight : -
Ref. : -

Date Received/Date Test Started : Apr 08, 2020

Applicant's Provided Care Instruction/Label :

-

For and on behalf of
Intertek Testing Services Hong Kong Limited




Teddy Y. N. Chung
Director



TEST REPORT

Original Sample Photo:



For any queries on this report, you are welcome to contact our customer service representatives:

EM3

Rebecca Chan at (852) 63290431 or email to rebecca.chan@intertek.com


Angie Yu (852) 98639123 or email to angie.yu@intertek.com

US3

Sandy Lo at (852) 93872308 or email to sandy.lo@intertek.com

Angie Yu (852) 98639123 or email to angie.yu@intertek.com

For and on behalf of
Intertek Testing Services Hong Kong Limited



Teddy Y. N. Chung
Director



TEST REPORT

Tests Conducted (As Requested By The Applicant)

1 Latex Particle Challenge GLP Report:

Summary: This procedure was performed to evaluate the non-viable particle filtration efficiency (PFE) of the test article. Monodispersed polystyrene latex spheres (PSL) were nebulized (atomized), dried, and passed through the test article. The particles that passed through the test article were enumerated using a laser particle counter.

A one-minute count was performed, with the test article in the system. A one-minute control count was performed, without a test article in the system, before and after each test article and the counts were averaged. Control counts were performed to determine the average number of particles delivered to the test articles. The filtration efficiency was calculated using the number of particles penetrating the test article compared to the average of the control values.

The procedure employed the basic particle filtration method described in ASTM F2299, with some exceptions; notably the procedure incorporated a non-neutralized challenge. In real case, particles carry a charge, thus this challenge represents a more natural state. The non-neutralized aerosol is also specified in the FDA guidance document on surgical face masks. All test method acceptance criteria were met.

Test side: Blue Side

Area Tested: 91.5 cm²

Particle Size: 0.1 μ m

Laboratory Conditions: 21 °C, 23% relative humidity (RH) at 0810; 21 °C, 22% relative humidity (RH) at 1017; 22 °C, 22% relative humidity (RH) at 1048

Average Filtration Efficiency: 99.52%

Standard Deviation: 0.062

Deviation Details: Controls and sample counts were conducted for one minute instead of an average of three one minute counts. This change shortens the total test time for each sample but will still provide an accurate determination of the particle counts. An equilibrate is a dwell period where the challenge is being applied to the test article for a certain period of time before test article counts are counted. The equilibrate period was reduced from 2 minutes to a minimum of 30 seconds which is sufficient time to clear the system of any residual particles, and establish a state of stable equilibrium before sample counts are taken. Test method acceptance criteria were met, results are valid.

Results:

Test Article Number	Test Article Counts	Average Control Counts	Filtration Efficiency (%)
1	64	12,892	99.50
2	67	12,949	99.48
3	49	13,345	99.63
4	67	13,360	99.50
5	67	13,198	99.49

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Test Method Acceptance Criteria: Ambient background particles detected through the test system must be below 1% of the challenge total (<100 particles).

Procedures:

Test Set-up: Testing was conducted in an ISO Class 5 (class 100) HEPA filtered hood. The inlet air to the test system was filtered through a 0.2 μ m rated air filter. The particle generator outlet was clamped off and the number of background particles within the test system was verified to be < 100 particles at 1 cubic foot per minute (CFM). The flow rate through the test system was maintained at 1 CFM \pm 5%.

An aliquot of the PSL was aerosolized using a particle generator, mixed with additional filtered air, dried and passed through the test system. The particles delivered were enumerated using a laser based particle counter.

Test Procedure: A test article was placed into the holder and the system was allowed to stabilize. The number of particles being delivered to the test article was determined (no medium in air stream) as one-minute control readings were taken prior to and after every test article. Control count averages were maintained at a level of 10,000-15,000 particles per cubic foot. One-minute counts were recorded for the test article between the control counts.

The PFE of each test article was determined by using the following equation:

$$\% PFE = \frac{C - T}{C} \times 100$$

C= Combined average of the control counts

T= Average test article counts

Compliance Statement: The test was conducted in accordance with the USFDA (21 CFR Parts 58, 210, 211 and 820) Regulations. This final report reflects the raw data.

Activity	Date
Study Initiation	30 Apr 2020
Phase Inspected by Quality Assurance: Latex Test	07 May 2020
Audit Results Reported to Study Director	13 May 2020
Audit Results Reports to Management	13 May 2020

TEST REPORT

Tests Conducted (As Requested By The Applicant)

Data Disposition: The study plan, raw data and final report from this study are archived at competent subcontractor laboratory.

Remark: The test was conducted by competent subcontractor lab.

End of Report

Except where explicitly agreed in writing, all work and services performed by Intertek is subject to our standard Terms and Conditions which can be obtained at our website: <http://www.intertek.com/terms/>. Intertek's responsibility and liability are limited to the terms and conditions of the agreement.

This report is made solely on the basis of your instructions and / or information and materials supplied by you and provide no warranty on the tested sample(s) be truly representative of the sample source. The report is not intended to be a recommendation for any particular course of action, you are responsible for acting as you see fit on the basis of the report results. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. This report does not discharge or release you from your legal obligations and duties to any other person. You are the only one authorized to permit copying or distribution of this report (and then only in its entirety). Any such third parties to whom this report may be circulated rely on the content of the report solely at their own risk.

This report shall not be reproduced, except in full.

